



Sanitary Sewer Overflow Annual Report Division of Surface Water

Date: 01/30/2023		
Facility Name: Garrettsville WWTP		
Ohio NPDES Permit Number: 3PB00016*MD		
Period Covered by Report: 01/01/2022 - 12/31/2022		
Contact Person: Jeffrey Sheehan		Title:
Mailing Address: PO Box 35, 8213 High Street		
City: Garrettsville	State: OH	Zip Code: 44231
Country: USA		
Sanitary Sewer Overflows Spreadsheet(attachment) :		
Water In Basement Occurrences Spreadsheet(attachment) : WIB 2022.xlsm		
Narrative analysis of WIB patterns by location, frequency and cause: <i>On 3/18/22 due to a partial blockage in the sanitary manhole N-63. Blockage created surcharge which backed up in the basement of 8105 South Park.</i>		
ADDITIONAL INFORMATION		
<i>Please add any additional comments or attachments below.</i>		
Sanitary sewer main was cleaned and later lined with a CIPP lining material.		
Certification		
<i>I certify under penalty of law that I have personally examined and am familiar with the information in this report and all attachments. Based on my inquiry of those persons immediately responsible for obtaining the information contained in the report, I believe that the information is true, accurate, and complete.</i>		
Name: Jeff Sheehan		Title: Superintendent
Signature(Electronically submitted by): Jeff Sheehan (User ID: jsheehan11)		Submission Date: 01/30/2023